Utah Department of Environmental Quality Division of Drinking Water

Public Water System Inventory Report

Run Date: 08/04/2011 12:11 pm

PWS ID: UTAH14021 Name: SHERWOOD WATER COMPANY

Legal Contact JOHNSON, SCOTT TYLER Rating: Not Approved

SCOTT TYLER JOHNSON Rating Date: 02/03/2010

Address: PO BOX 565 Activity Status: Active

DELTA, UT 84624

Phone Number: 435-864-2896

City Served (Area):

County: MILLARD COUNTY

Gal/Day Gal/Min

System Type: Community

Last Inv Update: 01/11/2011

Avg Daily Prod:

Activity Status Cd: Active

Last Snty Srv Dt: 10/12/2010

Total Dsgn Cap:

Surveyor: WADE TOLBERT

Total Emerg Cap:

Oper Period: 1/1 to 12/31

Contacts

Contact	Phone Numbers									
Type	Name	Title	Title Office		Email Address					
AC	JOHNSON, SCOTT TYLER	MANAGER	435-864-2896	435-864-8467	mbssj02@yahoo.com					

Service Connections

Connection			Number	_
Type	Meter Type Code	Meter Size	Connection	<u> </u>
Residential	Metered	0	73	
Combined	Unknown	0	25	
			98	— Total Svc Connection:

Storage

Total Storage: 162,000 GAL Number of Units: 2 Adequate Capacity: NO

No.	Name	Туре	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST00	2 STORAGE FACILITY ST002	Ground	138,000 GAL	Concrete		Α	NO
ST00	1 STORAGE FACILITY ST001	Ground	24,000 GAL	Steel		Α	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	SHERWOOD BOOSTER (ABANDO	I 1C		0			
PF002	UPGRADED SHERWOOD BOOST	EΑ		Р			

Distribution System

Pump Type	Total Dy	n Head	Pressure	Cross	Auhority
	ft H2O	P.S.I.	Adequate	Connection	Statement
			No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	SHERWOOD SHORES WEL	L Inactive	WL	8	30 GPM		Yes	GW	Permanent		
WS002	NORTH WELL	Active	WL		100 GPM		Yes	GW	Permanent	1/1 to 12/31	

^{*}Reports measured flow for wells, approved design capacity for all other sources.